Data Sheet | Item Number: 207-1331

Gelbox; Branch; for cables; with gel; 221, 2x73 Series; max. 4 mm² connectors; without splicing connectors; Size 1; gray

https://www.wago.com/207-1331



Note on Packaging Unit (PU) and Subpackaging Unit (SPU):

If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box.

If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- · Can be used immediately and accessed again later
- · Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Connection data

Connection 1	
Actuation type	Locking system

Physical data	
Width	32 mm / 1.26 inches
Height	17.8 mm / 0.701 inches
Depth	33.6 mm / 1.323 inches

Mechanical data	
Design	Size 1
Mounting type	Flying leads
Protection type	IPX8
Suitable	für Verbindungsklemmen 4 mm²

Material data	
Note (material data)	
	Information on material specifications can be found here
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	12 g

Data Sheet | Item Number: 207-1331

https://www.wago.com/207-1331



Environmental requirements

Ambient temperature (operation) $-55 \dots +85 \,^{\circ}\text{C}$ Ambient temperature (storage) $0 \dots +40 \,^{\circ}\text{C}$

 Commercial data

 ETIM 8.0
 EC001170

 ETIM 7.0
 EC001170

 PU (SPU)
 48 (4) pcs

 Country of origin
 DE

 GTIN
 4055143997799

 Customs tariff number
 85389099990

Environmental Product Compliance

RoHS Compliance Status Compliant, No Exemption

Approvals / Certificates

General approvals

Declarations of conformity and manufacturer's declarations



Approval	Standard	Certificate Name
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	400051938

Approval	Standard	Certificate Name
EU-Declaration of Conformity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

Downloads Documentation System Description System Description 207 Series Gel boxes System Description 207 Series Gel boxes pdf 1156.45 KB

Bid Text		
207-1331	xml 3.58 KB	$\underline{\downarrow}$
207-1331	docx 20.35 KB	$\overline{\downarrow}$

CAD/CAE-Data

CAD data

2D/3D Models
207-1331

CAE data

ZUKEN Portal
207-1331



Installation Notes

Data Sheet | Item Number: 207-1331

https://www.wago.com/207-1331



Installation



Open the Gelbox at the side latches.



Place the wired connector in the Gelbox.



Place the wired connector in the Gelbox.



Close the Gelbox.



Close latch securely.



Re-accessible:

- · Open the Gelbox.
- Remove the gel.Rewire with new components.



Lift the flap and pull the cover perforation



Press in the perforation on the sides.



Tear off the cover from the perforation.



As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out



If the flap is not required, tear off from the perforation.

Subject to changes. Please also observe the further product documentation!