### Data Sheet | Item Number: 207-1332

Gelbox; Branch; for cables; with gel; 221, 2x73 Series; max. 4 mm<sup>2</sup> connectors; without splicing connectors; Size 2; gray

https://www.wago.com/207-1332



Note on Packaging Unit (PU) and Subpackaging Unit (SPU):

If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box.

If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

#### Your benefits:

- Easy, fast and safe to use
- Can be used immediately and accessed again later
- · Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

# Connection data Connection 1 Actuation type Locking system

Physical data		
Width	45.9 mm / 1.807 inches	
Height	17.8 mm / 0.701 inches	
Depth	33.6 mm / 1.323 inches	

Mechanical data	
Design	Size 2
Mounting type	Flying leads
Protection type	IPX8
Suitable	für Verbindungsklemmen 4 mm²

Material data	
Note (material data)	
	<u>Information on material specifications can be found here</u>
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	18.4 g

# Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332



#### **Environmental requirements**

Ambient temperature (operation)  $-55 \dots +85 \,^{\circ}\text{C}$ Ambient temperature (storage)  $0 \dots +40 \,^{\circ}\text{C}$ 

 Commercial data

 ETIM 8.0
 EC001170

 ETIM 7.0
 EC001170

 PU (SPU)
 48 (4) pcs

 Country of origin
 DE

 GTIN
 4055143998017

 Customs tariff number
 85389099990

#### **Environmental Product Compliance**

RoHS Compliance Status Compliant,No Exemption

#### Approvals / Certificates

General approvals

Declarations of conformity and manufacturer's declarations



rungsinstitut

Approval	Standard	Certificate Name
VDE VDE Prüf- und Zertifizie-	EN 60998	400051938

# Downloads Documentation System Description System Description 207 Series Gel boxes System Description 207 Series Gel boxes pdf 207 Series Gel boxes 1191.37 KB

Bid Text		
207-1332	xml 3.58 KB	$\underline{\downarrow}$
207-1331	docx 20.38 KB	$\underline{\downarrow}$

# CAD/CAE-Data

CAD data

2D/3D Models
207-1332

CAE data

ZUKEN Portal
207-1332



#### **Installation Notes**

# Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332



#### Installation



Open the Gelbox at the side latches.



Place the wired connector in the Gelbox.



Place the wired connector in the Gelbox.



Close the Gelbox.



Close latch securely.



Re-accessible:

- · Open the Gelbox.
- Remove the gel.Rewire with new components.



Lift the flap and pull the cover perforation



Press in the perforation on the sides.



Tear off the cover from the perforation.



As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out



If the flap is not required, tear off from the perforation.

Subject to changes. Please also observe the further product documentation!