



Color: 🔳 gray

Note on Packaging Unit (PU) and Subpackaging Unit (SPU): If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box. If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- · Can be used immediately and accessed again later
- Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Connection data	
Connection 1	
Actuation type	Locking system

Physical data	
Width	57 mm / 2.244 inches
Height	21.3 mm / 0.839 inches
Depth	40.1 mm / 1.579 inches

Mechanical data	
Design	Size 3
Mounting type	Flying leads
Protection type	IPX8
Suitable	für Verbindungsklemmen 6 mm²

Data Sheet | Item Number: 207-1433

https://www.wago.com/207-1433



Material data	
Note (material data)	
	Information on material specifications can be found here
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	35.4 g

Environmental requirements	
Ambient temperature (operation)	-55 +85 ℃
Ambient temperature (storage)	0+40 °C

Commercial data	
ETIM 8.0	EC001170
ETIM 7.0	EC001170
PU (SPU)	24 (2) pcs
Country of origin	IT
GTIN	4055144097306
Customs tariff number	85389099990

Environmental Product Compliance	
RoHS Compliance Status	Compliant,No Exemption

Approvals / Certificates				
General approvals	Declarations of	Declarations of conformity and manufacturer's declarations		
\wedge				
VDE	Approval	Standard	Certificate Name	

	Approval	Standard	Certificate Name
Certificate Name	EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
	UK-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-

Downloads					
Documentation					
System Description			Bid Text		
System Description 207 Series Gel boxes	pdf 1156.45 KB	$\underline{\downarrow}$	207-1433	xml 3.58 KB	\downarrow
System Description 207 Series Gel boxes	pdf 1191.37 KB	\downarrow	207-1433	docx 20.42 KB	\downarrow

CAD/CAE-Data

Approval

VDE VDE Prüf- und Zertifizierungsinstitut Standard

EN 60669

Data Sheet | Item Number: 207-1433

https://www.wago.com/207-1433





Installation Notes

Installation



Open the Gelbox at the side latches.



Close latch securely.



 \checkmark

Place the wired connector in the Gelbox.



- Open the Gelbox. Remove the gel.
- Rewire with new components.



Place the wired connector in the Gelbox.



Close the Gelbox.



Lift the flap and pull the cover perforation forward.

Press in the perforation on the sides.



Tear off the cover from the perforation.



As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out



If the flap is not required, tear off from the perforation.

Subject to changes. Please also observe the further product documentation!