# MCB 1P 10kA C-80A 1.5M

Architecture	

Number of protected poles	1	
Number of poles	1 P	
Type of pole	1 P	
Curve	С	

### Connectivity

Bottom connection alignement for modular devices	Aligned terminal
Top connection alignement for modular devices	Aligned terminal

### Main electrical features

Frequency	50/60 Hz	
Rated short circuit breaking capacity Icn AC according 10 kA IEC60898-1		
Type of supply voltage	AC	
Rated operational voltage Ue	240/415 V	

## Voltage

Rated insulation voltage	500 V
Rated impulse withstand voltage	6000 V

# Electric current

Rated ultimate short-circuit breaking capacity Icu under 400V AC IEC 60947-2	10 kA
Rated short circuit breaking capacity Icn under 230V AC according IEC60898-1	10 kA
Rated short circuit breaking capacity Icn under 400V AC according IEC60898-1	10 kA
Rated service breaking capacity Ics AC according IEC 60947-2	75 %
Breaking capacity on 1 pole with 400 V NF 60947-2	4,5 kA
Breaking capacity on 1 pole with 415 V NF 60947-2	4,5 kA
Rated ultimate short-circuit breaking capacity Icu under 230V AC IEC 60947-2	10 kA
Rated ultimate short-circuit breaking capacity Icu under 240V AC IEC 60947-2	10 kA
Rated ultimate short-circuit breaking capacity Icu under 415V AC IEC 60947-2	10 kA
Magnetic regulating currrent at 40° C	5/10 ln
min/maxi threshold value of the AC thermal operation	1,13/1,45 ln

### Electric current / temperature

Rating current -15°C	109 A
Rating current -20°C	112 A
Rating current 0°C	99,2 A
Rating current 10°C	92,8 A
Rating current -10°C	106 A
Rating current 15°C	89,6 A
Rating current 20°C	86,4 A
Rating current 25°C	83,2 A
Rating current -25°C	115 A

Technical Properties	
Rating current 30°C	80 A
Rating current 35°C	77,6 A
Rating current 40°C	75,1 A
Rating current 45°C	72,6 A
Rating current 5°C	96 A
Rating current -5°C	102 A
Rating current 50°C	70 A
Rating current 55°C	67,2 A
Rating current 60°C	64,3 A
Rating current 0°C according to IEC 60947-2	106 A
Rating current 10°C according to IEC 60947-2	99,2 A
Rating current -10°C according to IEC 60947-2	112 A
Rating current 150°C according to IEC 60947-2	96 A
Rating current -15°C according to IEC 60947-2	115 A
Rating current 20°C according to IEC 60947-2	92,8 A
Rating current -20°C according to IEC 60947-2	118 A
Rating current 25°C according to IEC 60947-2	89.6 A
Rating current -25°C according to IEC 60947-2	122 A
Rating current 30°C according to IEC 60947-2	86,4 A
Rating current 35°C according to IEC 60947-2	83,2 A
Rating current 40°C according to IEC 60947-2	80 A
Rating current 45°C according to IEC 60947-2	77,6 A
Rating current 5°C according to IEC 60947-2	102 A
Rating current -5°C according to IEC 60947-2	109 A
Rating current 50°C according to IEC 60947-2	75,1 A
Rating current 55°C according to IEC 60947-2	72,6 A
Rating current 60°C according to IEC 60947-2	70 A
Rating current 65°C according to IEC 60947-2	67,2 A
riating carrent of according to 120 00541 2	01,2 A
Rating current 70°C according to IEC 60947-2	643 A
Rating current 70°C according to IEC 60947-2	64,3 A
Rating current 70°C according to IEC 60947-2  Current correction factors	64,3 A
Current correction factors	·
Current correction factors  Correction factor of rating current for 2 devices placed	·
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side	±1
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed	±1
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side	d 0,95
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices	d 0,95
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side	d 1 d 0,95 0,9
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power	d 1 d 0,95 0,9 d 0,85
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power loss per pole at In	d 1 d 0,95 0,9 d 0,85
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power loss per pole at In	d 1 d 0,95 0,9 d 0,85
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance	11 1 10,95 0,9 10,85 6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance  Electric endurance in number of cycles	6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance	11 1 10,95 0,9 10,85 6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance  Electric endurance in number of cycles	6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance  Electric endurance in number of cycles  Number of mechanical operations  Dimensions	6,18 W 6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance  Electric endurance in number of cycles  Number of mechanical operations  Dimensions  Depth of installed product	d 1 d 0,95 0,9 d 0,85 6,18 W 6,18 W
Current correction factors  Correction factor of rating current for 2 devices placed side-by-side  Correction factor of rating current for 3 devices placed side-by-side  Correction factor of rating current for 4 and 5 devices placed side-by-side  Correction factor of rating current for 6 devices placed side-by-side  Power  Power  Power loss per pole at In  Total power loss under IN  Endurance  Electric endurance in number of cycles  Number of mechanical operations  Dimensions	6,18 W 6,18 W 6,18 W

Insta	llation	, mounting

Type of top connection for modular devices	with screw
Tightening torque	3,5 to 5Nm
Type of bottom rail clip for modular devices	plastic
Type of top rail clip for modular devices	Plastic
Type of Bottom Connection for modular devices	with screw
Bottom removability for modular devices	yes
Top removability for modular devices	yes

#### Connection

Connection cross-section at output with screw, for flexible conductor	1/50 mm²
Connection cross-section of the access with screws, with flexible conductor	1/50 mm²
Connection cross-section at output with screw, for massive conductor	1/70 mm²
Connection cross-section for rigid conductor, upstream terminals with screws	1/70 mm²
Connection cross-sect. rigid cable	70mm²
Connection cross-sect. flexible conductor	50mm²
Nominal tightening torque bottom terminal	3,6 Nm
Nominal tightening torque top terminal	3,6 Nm
Type of connection	terminal with tightening compensation system
Connection cross section of access and exit with screws, for flexible conductor	1/50 mm <sup>2</sup>
Connection cross-section of input and output with screws, for massive conductors	1/70 mm <sup>2</sup>

# Standards

Standard text	EN 60898-1, IEC 60947-2, AS/NZS 60898-1
European directive WEEE	concerned

## Safety

Protection index IP	IP20	

### **Use conditions**

Degree of pollution according to IEC 60664 / IEC 60947-2	3
Altitude	2000 m
Storage temperature	-25 to 80 °C
Air humidity protection	for all climates

## temperatur

Temperature of calibration	30 °C	